

MOM BETWEEN M/s. JAYASHREE ELECTRODEVICES PVT LTD & NTPC LTD. KORBA CG.

Regarding commissioning of Belt watch, Pull Cord Indication System at CHP

Members Present

M/s. Jayashree Electrodevices Pvt. Ltd

Mr. R M Sanbhor, Supervisor Elect

Mr. P K Sahu Sr. Engineer Mktg.

M/s. NTPC LTD

Mr. P. K. Srivastava, Supdt. E/M

Mr. Ashish Agrawal Dy. Supdt. E/M

Meeting Ref No. KSC/03M/6.2160(A)/0831 DATE: 07.09.2007

Mr. R M Sanbhor & Mr. Sahu of M/s Jayashree reported on Dt 09/06/08 at NTPC Korba site. During their visit they have inspected the Panel installation and found all equipments in healthy condition. Panel supply is given & healthiness of all indication is ensured.

Next day onward sensor module fixing in Pull Cord switches & Commission of Pull Cord Indication system done for conveyor No. 19A & 20A Successfully. The same has been Checked & demonstrated for tripping & indication Single/Multiple operation of Pull Cord Switches. Pull Cord Indication System of conveyor No. 19A & 20A found working satisfactory

M/s Jayashree Engineers leaving the site on dt. 11/06/2008. The next visit is expected in last week of June'08 for further commissioning of remaining conveyors.

M/s. Jayashree Electrodevices Pvt. Ltd.




Mr. R M Sanbhor Supervisor Elect.




Mr. P K Sahu Sr. Engineer Mktg.

M/s. NTPC LTD


11-06-08

Mr. P. K. Srivastava, Supdt. E/M



Mr. Ashish Agrawal Dy. Supdt. E/M

Stamp: NTPC LTD, KORBA CG, dated 11-06-08